

Eligible Energy Efficiency Improvements

LIGHTING

Existing Fixture Type	Proposed Fixture Type	Max New Fixture Wattage	Incentive Per Fixture
T8 and T12	T8 4' 1-lamp	23	\$1.36
	T8 4' 2-lamp	47	\$2.04
	T8 4' 3-lamp	66	\$3.57
	T8 4' 4-lamp	86	\$4.42
MH 150-249W One for One Replacement	T8 4' 3-lamp (HB)	111	\$19.60
	T5 4' 2-lamp (HO HB)	117	
MH 250-399W One for One Replacement	T8 4' 4-lamp (HB)	154	\$33.00
	T5 4' 4-lamp (HO HB)	234	
MH 400-500W One for One Replacement	T8 4' 6-lamp (HB)	218	\$48.00
	T5 4' 6-lamp (HO HB)	234	
<u>Exit Signs</u> Incandescent Fluorescent	LED Exit	2	\$5.61

HB=High Bay, HO=High Output

HVAC

Category	Type	Minimum Required Efficiency	Incentive per Ton
Direct Expansion (DX)	Air Cooled	EER/SEER	
	<65,000 Btu's (~5 Ton)	11.0/14	\$29.00
	65,000 > 240,000 Btu's	11.5	\$67.00
	Water Cooled	EER/SEER	
	<65,000 Btu's (~5 Ton)	14/16	\$87.00
	65,000 > 240,000 Btu's	14	\$67.00
Heat Pump (HP)	Air Cooled	EER/SEER	
	<65,000 Btu's (~5 Ton)	11.6/14	\$76.00
	65,000 > 240,000 Btu's	11.5	\$104.00
	Water Cooled	EER/SEER	
	<65,000 Btu's (~5 Ton)	14/16	\$87.00
	65,000 > 240,000 Btu's	14	\$67.00